



South Asia

Compliance Document

No. CD2007MUM1007

This compliance document is issued to:

M/s Firefly Fire Pumps Private Limited,
C-7, MIDC, Gokul Shirgaon,
Kolhapur – 416 234
India

For Vehicle mounting centrifugal fire fighting pump

- FP NH EN 1028-1 10- 2000 / 40 – 250
- FP NH EN 1028-1 10- 3000 / 40 – 250
- FP NH EN 1028-1 10- 4000 / 40 – 250

These pumps comply with the essential health and Safety requirements of the following EC directives:

- Machinery Directive 98/37/EC

Applying following standards:

- EN 1028 – 1: 2002
- EN 1028 – 2 : 2002
- EN 1050:1996 / ISO 14121:1999

This is issued based on the testing & evaluations carried out vide following report for a representative model and fulfillment of technical documentation required.

- R2007MUM1001 issued by TÜV SÜD South Asia, Mumbai

It is only valid for the machinery and configuration described in conjunction with the test data referred as per above test reports.

Manufacturer may affix **CE marking** on the machine stated above, for the referred directives after signing the EC declaration of conformity. The machine manufacturer is responsible for the consistent manufacturing of the machine in conformity with the referred tests reports and standards.

Gokul Mahajan
Senior Manager- Product Certification
TÜV SÜD South Asia

Place: Mumbai

Date: 5th March 2007.

Note: Use of the TÜV product certification mark on the said product is not permitted.